

# Certificate of Compliance

**Date:** 05/09/2024

**Code or Series:** FT50/55 SERIES

**Product Name/Description:** Multipair foil screened instrumentation cables 110VAC 90°C

Rated insulation voltage 300V

Options: Overall foil screen, overall & individual foil screen and steel wire armour

Rated insulation voltage 300V

This product has been manufactured to meet the following standards and approvals.

**Standard(s):** AS/NZS1125, AS/NZS3808, IEC60332-1-2, IEC60079-14, IEC60332-3-22 & RoHS Compliant

**Technical Product Manager**

Dean Lipscombe

**Signed**

