

P: 09 264 1000 E: sales@firstflex.co.nz W: www.firstflex.co.nz 1 Toiawaka Road, Drury, 2579 PO Box 213, Pukekohe, 2340 Auckland, New Zealand

Certificate of Compliance

Date:	05/09/2024
Code or Series:	FT655-ESCS SERIES
Product Name/Description:	Multipair Overall & Individual Foil Screened Instrumentation
	Cables 0.6/1kV 90°C
FIRS	(600V Rated Insulation and 1.8mm Sheath Thickness)
This product has been manufactured to meet the following specification(s).	
	Powering Industry
Standard(s): AS/NZS1125, AS/NZS3808, IEC60332-1-2, IEC60079-14, ICE60332-3-22 & RoHS Compliant.	
Technical Product N	Manager Signed
Dean Lipscombe	Apseowl_

Disclosure: The information provided is to the best of our knowledge and is current at date of issue.

Firstflex reserves the right to make changes and modify this document as they see fit.